

MEMORANDUM

To: Interested Parties

From: Sebastian River Water Control District (SRWCD)

Subject: SRWCD Board of Supervisors Rule Adoption and Permit Condition

At the December 1, 2004 regularly scheduled quarterly meeting of the SRWCD Board of Supervisors, an interim stormwater discharge limitation rule was adopted by the SRWCD Board of Supervisors.

In summary, this interim rule adoption is applicable for new construction or change of use projects which discharge into or are constructed within the jurisdictional boundaries of the SRWCD and is noted as such;

For all new development/projects (exempting previously platted single family residential lots or tracts) a stormwater discharge limitation of two (2) inches per twenty-four (24) hours (**2"/24 hours**) for a twenty five (25) year---twenty four (24) hour storm event shall be provided to the SRWCD as part of the Permit Application process.

The limitation applies to the first seventy-two (72) hours during and after a twenty four (24) hour storm event. The two (2) inch limitation applies to any twenty four (24) hour period for hours zero (0) through seventy two (72).

In regards to this resolution and the associated 2 inch rule, Flood Plain Storage must be maintained. Cut and fill calculations demonstrating that compensating storage volume is being created to offset any proposed fill in the flood plain shall be prepared by an engineer registered and currently licensed to practice civil engineering in the State of Florida. Calculations shall be in accordance with Indian River County Stormwater Management Flood Protection Ordinance, (Ref: Chapter 930.07). The FEMA Flood Insurance Rate Map and a topographic survey (based on 1929 N.G.V.D.) of the subject site, prepared by a surveyor registered and currently licensed to practice surveying in the State of Florida, shall be used to establish the basis for calculations.

Any variance, or modification, to the above noted specific resolution or permit conditions will require the approval of the SRWCD Board of Supervisors

This interim stormwater discharge limitation will remain in effect until such time as the SRWCD Board of Supervisors accepts and formally adopts the results of the St. Johns River Water Management District's Basin Model relative to projects within the jurisdiction of the Sebastian River Water Control District.